

SpaceKeeper Console - Models “SRC” Guide Specifications

Part 1: General

- 1.1 The HVAC system is based on BULLDOG Reversing Heat Pump System.
- 1.2 The system will automatically provide the availability of heating or cooling functions 24 hours a day, 365 days a year without need for a changeover.
- 1.3 Model selection and performance shall be in accordance with the schedule on the drawings.
- 1.4 Mechanical cooling shall be enabled with Entering Condenser Water below 125°F. The system is designed to operate on 2 GPM/ton.
- 1.5 Each unit/chassis shall be pressure tested with Nitrogen on both the refrigerant and fluid (water) circuits followed by a helium leak detection program for both circuits. Units are then attached to the vacuum system for at least 2 hours and monitored.
- 1.6 Each unit shall be run tested for a minimum of 15 minutes with a water/ glycol solution to ensure 100% functionality in all modes of operation. Individual units/chassis shall be self-contained and complete when shipped from the factory.
- 1.7 Units shall be safety certified and bear a seal of approval from one of UL/ULC/ETL or ESA. All units must be AHRI certified and meet ASHRAE 90.1 minimum standard.
- 1.8 Manufacturer shall warrant the parts only of each unit for a period of 12 months from the start-up date or 18 months from the unit shipment date whichever occurs first.
- 1.9 Commissioning of the BULLDOG unit(s) shall be performed by a CGC trained technician. A commissioning report shall be provided by the commissioning technician for review and approval by the owner’s representative.
- 1.10 It is the contractor’s responsibility to have the system properly flushed and cleaned prior to commissioning.
- 1.11 Alternate proposals shall include consideration for equipment space requirements, pipe and equipment sizing, electrical installation impact, operation costs, sound implications and redesign fees.

Part 2: Mechanical Parts

The SpaceKeeper Console Heat Pump (SKC) is a ductless unit that consists of an external painted cabinet and a non-replaceable chassis.

2.1 Cabinet

- 2.1.1 The cabinet shall be constructed based on a frame and panel principle with lift off front access panel for maximum service access. The air is directly delivered through the punched grille at the top panel.
- 2.1.2 The external metal shall be heavy gauge lined with 1/2" acoustic insulation and painted with an epoxy powder and shall be finished with a light grey colour.
- 2.1.3 The unit comes with a standard 5" base. Other heights are available.

***(Optional)** If a unit mounted thermostat is required, the top panel will be equipped with sliding access door.

***(Optional)** Fresh air damper controlled by the heat pump and receptacle mounted on a back plate is available.

2.2 Chassis

- 2.2.1 The chassis must be a complete self-contained unit.
- 2.2.2 The chassis shall be complete with refrigeration circuit, hydronic circuit, blower assembly, controls and an internal corrosion resistant Stainless Steel insulated condensate drain pan.
- 2.2.3 The panels shall be insulated with 1/2" acoustic insulation and shall be easily removable and sufficiently large to allow access to all refrigeration components.
- 2.2.4 The chassis shall be complete with stainless steel braided flexible 24" hoses rated at 300psi. A clear reinforced condensate hose shall be provided with the chassis.
- 2.2.5 The plug connection shall provide positive disconnect of main power to the unit.

2.3 Blower and Motor

- 2.3.1 The complete blower section including motor shall be easily accessible and removable for service.
- 2.3.2 The blower shall be forward curved, DWDI centrifugal blower statically and dynamically balanced.
- 2.3.3 The blower is directly driven by a an Electronically Commutated (EC) motor that has integral thermal overload protection.
- 2.3.4 The fan motor shall be totally enclosed air over (TEAO) type.

2.4 Filter

- 2.4.1 The filter chamber shall be an integral part of the system located on return air path and should be serviceable from the front of the unit.
- 2.4.2 The filter shall be standard capacity, 1 inch thick "Disposable" type shipped with the unit.

***(Optional)** MERV 8 filters.



Part 3: Refrigeration Parts

3.1 Refrigeration System

3.1.1 The refrigeration circuit shall be available for operation on non-ozone depleting R454b refrigerant.

3.1.2 The refrigeration circuit shall have the following components:

- Thermal Expansion Valve with external equalizer – bi-directional
- Filter dryer – bi-directional
- High pressure cut-out
- High pressure service port
- Low pressure cut-out
- Low pressure service port
- Reversing valve

***(Optional)** Refrigerant Sight Glass

3.1.3 The service ports shall be located to facilitate field service with unit in place.

3.1.4 All refrigerant piping shall be of type ACR copper pipe.

3.1.5 The refrigerant circuit and components shall be factory assembled in a sealed, leak and performance tested, properly charged system.

3.1.6 The sealed refrigerant circuit shall be certified for 600 PSIG working condensing pressure.

3.2 Compressor

3.2.1 The compressor shall be sealed hermetic rotary type.

3.2.2 The compressor shall be externally isolated on rubber mounts and connected to refrigerant circuit with floating piping to minimize sound transmission.

3.2.3 The compressor motor shall have integral thermal overload protection.

3.2.4 The compressor shall be provided with a 5-minute restart delay to avoid compressor short cycling and low-pressure lockout.

3.3 Air to Refrigerant Heat Exchanger

3.3.1 The refrigerant to air heat exchanger shall be aluminum fin and copper tube construction rated to withstand 470 PSI refrigerant working pressure.

3.3.2 The coil shall have a maximum face velocity of 500 FPM.

3.3.3 A Stainless-Steel insulated condensate drain pan shall be provided under the coil.

3.3.4 The unit shall be supplied with a ¾" ID condensate hose.



3.4 Water to Refrigerant Heat Exchanger

- 3.4.1 The condenser shall be of the brazed plate type that can withstand pressure up to 600 psi. A 20-mesh size strainer will be installed as standard.

3.5 Valve Configuration – Factory Installed

- 3.5.1 All units shall be supplied with one 2-way control valve for variable water flow pumping systems. If the system is bottom fed, all units at the top of each riser shall only be wired for continuous water flow.

***(Optional)** Flow limiting device available upon request.

Part 4: Control Systems

4.1 System

- 4.1.1 The unit shall be complete with a standard microprocessor controlled electronic circuit board.
- 4.1.2 The control panel shall be supplied with individual 24 VAC control transformer.
- 4.1.3 The control panel shall have LED indicators displaying thermostat call, unit operation and alarms.
- 4.1.4 Units with R454B refrigerant charge more than 62.5 oz are equipped with refrigerant leak detector sensor and a board that in case of a leak detection it will disconnect the compressor and run the circulation fan.
- 4.1.5 The control board shall operate with:
- A 24-volt thermostat
 - Onboard fuse protection
- 4.1.6 A remote alarm contact is available for connection to alarm monitor by others – monitored and wired by others.
- 4.1.7 BMS override function available to disable compressor only or disable unit. BMS override and wiring by others.
- 4.1.8 Condensate High Level Monitor and alarm is available.

***(Optional)** Different types of BULLDOG thermostats are available upon request.

4.2 Alarms

The standard Control Panel shall have the following standard alarms:

- Low Coil Temperature
- High Leaving Water Temperature
- Low Discharge Air Temperature
- Low Refrigerant Pressure
- High Refrigerant Pressure
- High Condensate Level